

Discharge Point Monitoring Results Ballyclerihan WWTP - 2011

Parameter	BOD (mg/l)	COD (mg/l)	SS (mg/l)	Amm (mg/l)	Ortho P (mg/l)	TN (mg/l)	pH
ELV (mg/l)	10	125	10	1	0.5	20	6 to 9
January	4	27	5	0.1	0.05	3.4	7.4
February	4	15	5	0.1	0.06	4.3	7.4
March	2	25	5	0.1	1.25	2.3	7.5
April	2	22	5	0.1	0.06	2	7.3
May	2	20	5	0.1	0.05	2.3	7.2
June	2	20	5	0.1	0.03	2.1	7.1
July	2	21	6	0.1	0.07	2.3	7.7
August	5	17	3	0.1	0.15	1.7	7.3
September	6	15	3	0.1	0.09	2.7	7.7
October	2	15	3	0.1	0.32	3	7.4
November	2	15	3	0.1	0.07	10.6	7.4
December	2	15	3	0.1	0.24	10.1	7.5