

* Accredited **Sub-Contract ***Accredited Sub-Contract				Parameter	Coliform Bacteria	Colony Count @ 22°C	Colour (Apparent)	Conductivity @ 20°C	E Coli	Free Chlorine	Nitrate NO3	Odour (D)	pH	Taste (D)	Total Chlorine	Turbidity	Aluminium	Fluoride
GWS - Group A Parameters				Max.	0	200	20	2500	0	2	50	--	9.5	--	2	1	200	0.8
				Min.	--	--	--	--	--	--	--	--	6.5	--	--	--	--	0.6
				Test Method	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Entity Reference	Sample Date	Reason		MPN/100mls	no./1ml	Pt-Co	µS/cm	MPN/100mls	mg/l	mg/l	Descriptive	pH units	Descriptive	mg/l	NTU	µg/l	mg/l
Abbeyville Lorrha	2800PRI2156	11-Mar-2020	Compliance	-	0 ***	21 ***	< 2 ***	672 ***	0 ***	0.17	32 ***	ok	7.2 ***	ok	0.27	0.2 ***		
Abbeyville Lorrha	2800PRI2156	19-May-2020	Compliance	-	0 ***	5 ***	< 2 ***	719 ***	0 ***	0.55	29 ***	ok	7.2 ***	ok	0.61	0.7 ***		
Ardcroyne	2800PRI2043	15-Jan-2020	Compliance	-	0 ***	0 ***	11.3 ***	665 ***	0 ***	0.34	39 ***	OK	7.2 ***	OK	0.49	0.2 ***		
Ardcroyne	2800PRI2043	11-Mar-2020	Compliance	-	0 ***	< 1 ***	8 ***	674 ***	0 ***	0.48	48 ***	ok	7.3 ***	ok	0.62	0.2 ***		
Ardcroyne	2800PRI2043	9-June-2020	Compliance	-	0 ***	12 ***	< 2 ***	677 ***	0 ***	0.5	36 ***	ok	7.4 ***	ok	0.52	0.1 ***		
Ardcroyne	2800PRI2043	7-Oct-2020	Compliance	-	0 ***	< 1 ***	4.5 ***	638 ***	0 ***	0.62	30 ***	ok	7.2 ***	ok	0.72	0.2 ***		
Ashill	2800PRI2126	23-June-2020	Compliance	-	0 ***	< 1 ***	2.9 ***	685 ***	0 ***	0.15	12 ***	ok	7.2 ***	ok	0.28	0.3 ***		
Ashill	2800PRI2126	13-Oct-2020	Compliance	-	0 ***	1 ***	4.7 ***	689 ***	0 ***	0.18	7.3 ***	OK	7.1 ***	OK	0.55	0.3 ***		
Ballinderry	2800PRI2021	11-Mar-2020	Compliance	-	0 ***	1 ***	3 ***	639 ***	0 ***	0.53	23 ***	ok	7.2 ***	ok	0.63	< 0.1 ***		
Ballinderry	2800PRI2021	28-Oct-2020	Compliance	-	0 ***	1 ***	4.1 ***	679 ***	0 ***	0.58	40 ***	ok	7.2 ***	ok	0.63	0.3 ***		
Barnane	2800PRI2078	21-Jan-2020	Compliance	-	0 ***	2 ***	< 2 ***	524 ***	0 ***	0.89	10 ***	OK	7.2 ***	OK	1.03	0.1 ***		
Barnane	2800PRI2078	24-June-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	509 ***	0 ***	0.1	7.8 ***	ok	7.2 ***	ok	0.6	0.2 ***		
Bawn/Kilriffith	2800PRI2001	15-Jan-2020	Compliance	-	0 ***	2 ***	< 2 ***	564 ***	0 ***	0.27	18 ***	OK	7.4 ***	OK	0.32	0.2 ***		
Bawn/Kilriffith	2800PRI2001	16-Sep-2020	Compliance	-	0 ***	2 ***	< 2 ***	524 ***	0 ***	0.33	13 ***	ok	7.5 ***	ok	0.4	0.5 ***		
Bawn/Kilriffith	2800PRI2001	22-Oct-2020	Compliance	-	0 ***	7 ***	2.9 ***	520 ***	0 ***	0.37	14 ***	ok	7.4 ***	ok	0.45	0.6 ***		
Bawn/Kilriffith	2800PRI2001	18-Nov-2020	Compliance	-	0 ***	< 1 ***	2.1 ***	581 ***	0 ***	0.49	20 ***	ok	7.6 ***	ok	0.55	0.4 ***		
Brittas	2800PRI2165	21-Jan-2020	Compliance	-	0 ***	5 ***	< 2 ***	648 ***	0 ***	0.03	7 ***	OK	7.4 ***	OK	0.06	0.1 ***		
Brittas	2800PRI2165	23-June-2020	Compliance	-	21 ***	70 ***	2.1 ***	620 ***	0 ***	0	7.4 ***	ok	7.4 ***	ok	0	< 0.1 ***		
Carrigahorig / Milford	2800PRI2027	19-May-2020	Compliance	-	0 ***	5 ***	< 2 ***	688 ***	0 ***	0.47	49 ***	ok	7.3 ***	ok	0.52	0.6 ***		
Carrigahorig / Milford	2800PRI2027	9-June-2020	Compliance	-	0 ***	3 ***	< 2 ***	683 ***	0 ***	0.33	42 ***	ok	7.4 ***	ok	0.34	0.1 ***		
Carrigahorig / Milford	2800PRI2027	18-Aug-2020	Compliance	-	0 ***	2 ***	< 2 ***	651 ***	0 ***	0.18	40 ***	ok	7.3 ***	ok	0.23	< 0.1 ***		
Carrigahorig / Milford	2800PRI2027	30-Oct-2020	Compliance	-	0 ***	1 ***	< 2 ***	654 ***	0 ***	0.17	41 ***	ok	7.5 ***	ok	0.19	0.2 ***		
Castelcranna / Carrigatogher	2800PRI2041	15-Jan-2020	Compliance	-	0 ***	0 ***	2.3 ***	489 ***	0 ***	0	< 0.66 ***	OK	7.4 ***	OK	0.03	0.3 ***		
Castelcranna / Carrigatogher	2800PRI2041	9-Oct-2020	Compliance	-	0 ***	8 ***	< 2 ***	497 ***	0 ***	0	< 0.66 ***	ok	7.6 ***	ok	0	0.2 ***		
Castleliney A	2800PRI2045	21-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	687 ***	0 ***	0.37	49 ***	OK	7.2 ***	OK	0.45	0.3 ***		
Castleliney A	2800PRI2045	24-June-2020	Compliance	-	0 ***	< 1 ***	3.5 ***	674 ***	0 ***	0	36 ***	ok	7.3 ***	ok	0	0.4 ***		
Clobanna	2800PRI2518	21-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	650 ***	0 ***	0.09	35 ***	OK	7.2 ***	OK	0.18	0.3 ***		
Clobanna	2800PRI2518	23-June-2020	Compliance	-	0 ***	2 ***	< 2 ***	653 ***	0 ***	0	25 ***	ok	7.2 ***	ok	0	0.1 ***		
Corbally Portroe	2800PRI2311	11-Aug-2020	Compliance	-	0 ***	4 ***	2.3 ***	202 ***	0 ***		6.1 ***	ok	7.1 ***	ok		0.2 ***		
Corbally Portroe	2800PRI2311	16-Sep-2020	Compliance	-	0 ***	5 ***	2.3 ***	168 ***	0 ***		8 ***	ok	6.7 ***	ok		0.2 ***		
Couraguneen	2800PRI2387	29-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	477 ***	0 ***		7.9 ***	OK	7.6 ***	OK		0.2 ***		
Couraguneen	2800PRI2387	14-Oct-2020	Compliance	-	0 ***	2 ***	< 2 ***	461 ***	0 ***		8.8 ***	ok	7.6 ***	ok		0.2 ***		
Cunnahurt /Knockalton	2800PRI2009	12-Feb-2020	Compliance	-	0 ***	10 ***	7.4 ***	706 ***	0 ***	0	35 ***	OK	7.2 ***	OK	0	0.9 ***		
Cunnahurt /Knockalton	2800PRI2009	7-Oct-2020	Compliance	-	0 ***	< 1 ***	2.2 ***	716 ***	0 ***	0.31	41 ***	ok	7.2 ***	ok	0.36	0.2 ***		
Drombane Ballina	2800PRI2100	28-Jan-2020	Compliance	-	0 ***	4 ***	< 2 ***	380 ***	0 ***	0	12 ***	OK	7.4 ***	OK	0	0.1 ***		
Drombane Ballina	2800PRI2100	7-Oct-2020	Compliance	-	0 ***	2 ***	4.9 ***	361 ***	0 ***	0	13 ***	ok	7.4 ***	ok	0	< 0.1 ***		
Drombane Upperchurch	2800PRI2031	5-Feb-2020	Compliance	-	0 ***	0 ***	< 2 ***	421 ***	0 ***	0.68	6.2 ***	OK	7.7 ***	OK	0.75	0.2 ***		
Drombane Upperchurch	2800PRI2031	23-June-2020	Compliance	-	2 ***	5 ***	2 ***	437 ***	2 ***	0.57	6.3 ***	ok	7.6 ***	ok	0.62	0.3 ***		
Elmhill / Ballymackey	2800PRI2018	12-Feb-2020	Compliance	-	0 ***	0 ***	2.9 ***	435 ***	0 ***	0.37	8.7 ***	OK	7.2 ***	OK	0.64	0.1 ***		
Elmhill / Ballymackey	2800PRI2018	28-Oct-2020	Compliance	-	0 ***	1 ***	< 2 ***	398 ***	0 ***	0.2	3.9 ***	ok	7.2 ***	ok	0.4	0.2 ***	19 ***	0.62 ***
Fantane	2800PRI2051	21-Jan-2020	Compliance	-	0 ***	45 ***	< 2 ***	480 ***	0 ***	0.39	38 ***	OK	7.2 ***	OK	0.48	0.1 ***		
Fantane	2800PRI2051	22-Oct-2020	Compliance	-	0 ***	1 ***	2.6 ***	437 ***	0 ***	0.68	36 ***	ok	7.1 ***	ok	0.85	0.1 ***		
Frolic Carney	2800PRI2034	19-May-2020	Compliance	-	0 ***	16 ***	< 2 ***	681 ***	0 ***	0.74	35 ***	ok	7.2 ***	ok	0.76	0.6 ***		
Frolic Carney	2800PRI2034	22-July-2020	Compliance	-	0 ***	2 ***	< 2 ***	643 ***	0 ***	0.66	28 ***	ok	7.3 ***	ok	0.85	0.2 ***		
Garrynamona	2800PRI2024	22-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	718 ***	0 ***	0	47 ***	OK	7.3 ***	OK	0	0.1 ***		
Garrynamona	2800PRI2024	12-Mar-2020	Compliance	-	0 ***	7 ***	< 2 ***	665 ***	0 ***	0.29	28 ***	ok	7 ***	ok	0.36	0.1 ***		
Garrynamona	2800PRI2024	23-June-2020	Compliance	-	0 ***	1 ***	< 2 ***	685 ***	0 ***	0.26	31 ***	ok	7.3 ***	ok	0.3	0.1 ***		
Garrynamona	2800PRI2024	23-Oct-2020	Compliance	-	0 ***	1 ***	< 2 ***	692 ***	0 ***	0.72	29 ***	ok	7.3 ***	ok	0.81	0.3 ***		
Graigie Pouldine Zone 2: Turtulla	2800PRI2250	22-Jan-2020	Compliance	-	0 ***	0 ***	2.2 ***	639 ***	0 ***	0.58	19 ***	OK	7.4 ***	OK	0.72	0.3 ***		
Graigie Pouldine Zone 2: Turtulla	2800PRI2250	13-Oct-2020	Compliance	-	0 ***	1 ***	3.1 ***	639 ***	0 ***	0.31	21 ***	OK	7.2 ***	OK	0.37	0.3 ***		
Gurteenakilla	2800PRI2094	20-May-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	423 ***	0 ***	0.6	31 ***	ok	7.1 ***	ok	0.66	0.1 ***		
Gurteenakilla	2800PRI2094	21-July-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	406 ***	0 ***	0.9	27 ***	ok	7 ***	ok	1	0.2 ***		
Inchirourke	2900PRI0145	12-Mar-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	704 ***	0 ***	0.94	29 ***	ok	7.1 ***	ok	1.02	0.1 ***		
Inchirourke	2900PRI0145	5-Nov-2020	Compliance	-	0 ***	1 ***	< 2 ***	690 ***	0 ***	0.65	32 ***	OK	7.3 ***	OK	0.7	0.9 ***		
Kilbarron	2800PRI2005	11-Mar-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	663 ***	0 ***	0.34	25 ***	ok	7.2 ***	ok	0.39	0.1 ***		
Kilbarron	2800PRI2005	7-Oct-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	649 ***	0 ***	0.58	25 ***	ok	7.2 ***	ok	0.59	0.1 ***		

* Accredited **Sub-Contract ***Accredited Sub-Contract				Parameter	Coliform Bacteria	Colony Count @ 22°C	Colour (Apparent)	Conductivity @ 20°C	E Coli	Free Chlorine	Nitrate NO3	Odour (D)	pH	Taste (D)	Total Chlorine	Turbidity	Aluminium	Fluoride
GWS - Group A Parameters				Max.	0	200	20	2500	0	2	50	--	9.5	--	2	1	200	0.8
				Min.	--	--	--	--	--	--	--	--	6.5	--	--	--	--	0.6
				Test Method	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Entity Reference	Sample Date	Reason		MPN/100mls	no./1ml	Pt-Co	µS/cm	MPN/100mls	mg/l	mg/l	Descriptive	pH units	Descriptive	mg/l	NTU	µg/l	mg/l
Kilcoran Group Water Scheme	2900PRI0226	3-Mar-2020	Compliance	-	0 ***	6 ***	< 2 ***	195 ***	0 ***	0	2.6 ***	NONE	6.5 ***	ok	0	0.5 ***		
Kilcoran Group Water Scheme	2900PRI0226	12-June-2020	Compliance	-	0 ***	0 ***	2 ***	236 ***	0 ***	0.46	5.8 ***	NONE	6.8 ***	OK	0.48	0.1 ***		
Killeen A	2800PRI2155	11-Feb-2020	Compliance	-	0 ***	0 ***	< 2 ***	257 ***	0 ***	0	3.8 ***	OK	7.3 ***	OK	0.13	0.4 ***		
Killeen A	2800PRI2155	20-May-2020	Compliance	-	0 ***	2 ***	< 2 ***	382 ***	0 ***	0.61	11 ***	ok	7.4 ***	ok	0.69	0.1 ***		
Knock Roscrea	2800PRI2093	29-Jan-2020	Compliance	-	0 ***	17 ***	< 2 ***	472 ***	0 ***	0	14 ***	OK	7.1 ***	OK	0	0.1 ***		
Knock Roscrea	2800PRI2093	14-Oct-2020	Compliance	-	0 ***	2 ***	< 2 ***	468 ***	0 ***	0	16 ***	ok	7.1 ***	ok	0	0.3 ***		
Lacka	2800PRI2071	18-Feb-2020	Compliance	-	0 ***	0 ***	< 2 ***	627 ***	0 ***	1.3	18 ***	ok	7.3 ***	ok	1.39	0.2 ***		
Lacka	2800PRI2071	28-Oct-2020	Compliance	-	0 ***	212 ***	3.2 ***	623 ***	0 ***	0.58	17 ***	ok	7.2 ***	ok	0.6	0.1 ***		
Lisheenacloonta	2800PRI2223	15-Jan-2020	Compliance	-	0 ***	4 ***	< 2 ***	677 ***	0 ***	0.5	51 ***	OK	7.2 ***	OK	0.54	0.1 ***		
Lisheenacloonta	2800PRI2223	20-May-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	722 ***	0 ***	0.93	54 ***	ok	7.2 ***	ok	0.97	0.2 ***		
Luska	2800PRI2104	15-Jan-2020	Compliance	-	0 ***	0 ***	2.3 ***	668 ***	0 ***	0.03	43 ***	OK	7.3 ***	OK	0.14	0.3 ***		
Luska	2800PRI2104	11-Mar-2020	Compliance	-	0 ***	9 ***	2.6 ***	665 ***	0 ***	0.1	38 ***	ok	7 ***	ok	0.14	0.2 ***		
Mota/ Coolbawn	2800PRI2243	15-Jan-2020	Compliance	-	0 ***	2 ***	< 2 ***	728 ***	0 ***	0.15	10 ***	OK	7.2 ***	OK	0.19	0.1 ***		
Mota/ Coolbawn	2800PRI2243	19-May-2020	Compliance	-	0 ***	9 ***	< 2 ***	746 ***	0 ***	0.65	11 ***	ok	7.4 ***	ok	0.68	0.9 ***		
Moyne	2800PRI2030	22-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	666 ***	0 ***	0.15	38 ***	OK	7.3 ***	OK	0.27	0.1 ***		
Moyne	2800PRI2030	12-Mar-2020	Compliance	-	0 ***	6 ***	< 2 ***	641 ***	0 ***	0.18	33 ***	ok	7.2 ***	ok	0.28	< 0.1 ***		
Moyne	2800PRI2030	24-June-2020	Compliance	-	0 ***	252 ***	5.6 ***	725 ***	0 ***	0.3	37 ***	ok	7.2 ***	ok	0.39	0.1 ***		
Moyne	2800PRI2030	23-Oct-2020	Compliance	-	0 ***	2 ***	8.3 ***	690 ***	0 ***	0.22	34 ***	ok	7.2 ***	ok	0.31	0.3 ***		
Newhill	2800PRI2109	22-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	751 ***	0 ***	0	31 ***	OK	7.3 ***	OK	0.02	0.1 ***		
Newhill	2800PRI2109	11-Aug-2020	Compliance	-	0 ***	172 ***	< 2 ***	745 ***	0 ***	0	30 ***	ok	7.4 ***	ok	0	< 0.1 ***		
Patrickswell	2800PRI2137	20-May-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	310 ***	0 ***	0.66	29 ***	ok	7 ***	ok	0.73	0.3 ***		
Patrickswell	2800PRI2137	21-July-2020	Compliance	-	0 ***	3 ***	< 2 ***	358 ***	0 ***	0.43	34 ***	ok	6.8 ***	ok	0.49	0.2 ***		
Patrickswell	2800PRI2137	7-Oct-2020	Compliance	-	0 ***	< 1 ***	3 ***	277 ***	0 ***	0.43	21 ***	ok	6.9 ***	ok	0.47	0.4 ***		
Patrickswell	2800PRI2137	18-Nov-2020	Compliance	-	0 ***	1 ***	2.8 ***	285 ***	0 ***	0.26	28 ***	ok	6.9 ***	ok	0.32	0.4 ***		
Rahealty	2800PRI2190	21-Jan-2020	Compliance	-	0 ***	0 ***	< 2 ***	695 ***	0 ***	0.31	16 ***	OK	7.2 ***	OK	0.4	0.2 ***		
Rahealty	2800PRI2190	12-Mar-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	691 ***	0 ***	0.22	15 ***	ok	7.1 ***	ok	0.27	< 0.1 ***		
Rahealty	2800PRI2190	24-June-2020	Compliance	-	0 ***	< 1 ***	2 ***	697 ***	0 ***	1.93	16 ***	ok	7.4 ***	ok	1.96	1.5 ***		
Rahealty	2800PRI2190	13-Oct-2020	Compliance	-	0 ***	1 ***	2.3 ***	674 ***	0 ***	1.04	16 ***	OK	7.2 ***	OK	1.06	1.4 ***		
Rathfalla	2800PRI2285	22-Jan-2020	Compliance	-	0 ***	1 ***	< 2 ***	653 ***	0 ***		29 ***	OK	7.3 ***	OK		0.1 ***		
Rathfalla	2800PRI2285	20-May-2020	Compliance	-	0 ***	< 1 ***	< 2 ***	685 ***	0 ***		32 ***	ok	7.5 ***	ok		0.1 ***		
Shallee	2800PRI2284	9-Nov-2020	Compliance	-	0 ***	< 1 ***	2.9 ***	578 ***	0 ***	0	8 ***	ok	7.4 ***	ok	0	0.1 ***		
Shallee	2800PRI2284	9-Dec-2020	Compliance	-	0 ***	10 ***	< 2 ***	597 ***	0 ***	0	16 ***	OK	7.7 ***	OK	0	0.6 ***		
The Pike Ballingarry	2800PRI2198	18-Feb-2020	Compliance	-	0 ***	3 ***	< 2 ***	572 ***	0 ***	0.19	14 ***	ok	7.2 ***	ok	0.3	0.1 ***		
The Pike Ballingarry	2800PRI2198	27-May-2020	Compliance	-	0 ***	5 ***	< 2 ***	647 ***	0 ***	0.15	14 ***	ok	7.6 ***	ok	0.32	0.2 ***		
Tonagha / Drish / Galboola	2800PRI2108	22-Jan-2020	Compliance	-	0 ***	0 ***	3.5 ***	718 ***	0 ***	0.31	34 ***	OK	7.2 ***	OK	0.47	0.1 ***		
Tonagha / Drish / Galboola	2800PRI2108	13-Oct-2020	Compliance	-	0 ***	1 ***	4.6 ***	681 ***	0 ***	0.24	25 ***	OK	7 ***	OK	0.31	0.2 ***		