

			Parameter	Coliform Bacter	Conductivity @	E Coli	pH	Turbidity	Colour (Appare	Free Chlorine	Nitrate NO3	Total Chlorine	1,2-Dichloroeth	2,3,6-TBA Trich	2,4-D Acid Her	2,4-DB Acid He	Aluminium	Ammonium NH
			Max.	0	2500	0	9.5	4	20	--	50	--	3	--	--	--	200	0.3
			Min.	--	--	--	6.5	--	--	--	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclus	MPN/100mls	µS/cm	MPN/100mls	pH units	NTU	Pt-Co	mg/l	mg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	mg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	0	701	0	7.2	< 0.2	< 5	0.22	6.71	0.28	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	0	692	0	7.4	< 0.2	< 5	0.26	21.01	0.27	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	0	668	0	7.5	0.63	< 5	0.44	41.32	0.46	< 0.2	< 0.005	< 0.005	< 0.005	14	0.07
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	0	519	0	7.7	< 0.2	< 5	0.38	< 1.11	0.4	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Castleliney A	GWS - Group B Parameters	19-July-2023	-	0	714	0	7.2	< 0.2	< 5	0.05	30.02	0.07	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	0	169	0	6.5	< 0.2	< 5		6.12		< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	0	485	0	7.7	< 0.2	< 5		8.58		< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	0	749	0	7.5	< 0.2	< 5	0.32	37.92	0.41	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	0	392	0	7.4	< 0.2	< 5	0.21	12.05	0.26	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	0	679	0	7.2	< 0.2	< 5	0.27	30.48	0.33	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	0	290	0	7.6	0.3	< 5	0.98	6.75	1.1	< 0.2	< 0.005	< 0.005	< 0.005	31	< 0.03
Glenacunna	GWS - Group B Parameters	10-May-2023	-	0	71	0	5.3	0.39	< 5		6.4		< 0.2	< 0.005	< 0.005	< 0.005	24	< 0.03
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	0	684	0	7.7	0.58	< 5	0.95	35.28	1.25	< 0.2	< 0.005	< 0.005	< 0.005	33	< 0.03
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	0	670	0	7.4	< 0.2	< 5	0.55	18.99	0.67	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	0	430	0	6.9	< 0.2	< 5	0.52	27.03	0.63	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	0	639	0	7.3	0.57	< 5	0.91	16.6	1.06	< 0.2	< 0.005	< 0.005	< 0.005	21	< 0.03
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	0	218	0	6.6	0.28	< 5	0.5	2.22	0.52	< 0.2	< 0.005	< 0.005	< 0.005	16	< 0.03
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	78	340	1	7.1	< 0.2	< 5	0	10.7	0	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	0	478	0	7.2	< 0.2	< 5	0.02	13.72	0.03	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Lacka	GWS - Group B Parameters	4-Sep-2023	-	0	677	0	7.4	< 0.2	< 5	0.23	16.28	0.23	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	0	718	0	7.3	< 0.2	< 5	0.18	45.87	0.21	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Luska	GWS - Group B Parameters	29-Aug-2023	-	0	783	0	7.3	< 0.2	< 5	0.16	63.22	0.33	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	0	734	0	7.3	< 0.2	< 5	0.26	9.96	0.3	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Newhill	GWS - Group B Parameters	23-Aug-2023	-	0	776	0	7.3	< 0.2	< 5	0.12	29.53	0.21	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	0	260	0	7.1	0.76	6	0.75	23.71	0.84	< 0.2	< 0.005	< 0.005	< 0.005	16	< 0.03
Rathfalla	GWS - Group B Parameters	13-June-2023	-	0	662	0	7.2	< 0.2	< 5		25.41		< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Shallee	GWS - Group B Parameters	13-Sep-2023	-	0	632	0	7.3	< 0.2	< 5	0.14	10.06	0.23	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	0	585	0	7.5	< 0.2	< 5	0.04	11.68	0.1	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	0	739	0	7.2	< 0.2	< 5	0.18	18.03	0.38	< 0.2	< 0.005	< 0.005	< 0.005	< 10	< 0.03

			Parameter	Antimony	Arsenic	Atrazine	Bentazone	Benzene	Benzo(a)pyrene	Benzo(b)fluoranthene	Benzo(ghi)perylene	Benzo(k)fluoranthene	Boron	Bromate	Bromodichloroethane	Bromoform	Cadmium	Chlorfenvinphos
			Max.	5	10	--	--	1	0.01	--	--	--	1	10	--	--	5	--
			Min.	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclusion	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.04	< 2	3	1	< 0.45	< 0.005
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	3	< 0.45	< 0.005
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	1	< 0.45	< 0.005
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.11	< 2	2	3	< 0.45	< 0.005
Castleliney A	GWS - Group B Parameters	19-July-2023	-	< 1	< 1	0.007	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.04	< 2	1	< 1	< 0.45	< 0.005
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	< 1	< 0.45	< 0.005
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	< 1	< 1	< 0.45	< 0.005
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.04	< 2	1	3	< 0.45	< 0.005
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	1	< 0.45	< 0.005
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	1	4	< 0.45	< 0.005
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	2	1	< 0.45	< 0.005
Glenacunna	GWS - Group B Parameters	10-May-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	< 1	< 0.45	< 0.005
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	< 1	2	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	4	20	1	< 0.45	< 0.005
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.02	< 2	1	2	< 0.45	< 0.005
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	2	3	< 0.45	< 0.005
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	7	1	< 0.45	< 0.005
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	1	1	< 0.45	< 0.005
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	2	3	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.02	< 2	1	< 1	< 0.45	< 0.005
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.04	< 2	< 1	2	< 0.45	< 0.005
Lacka	GWS - Group B Parameters	4-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	< 1	1	< 0.45	< 0.005
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	1	< 1	< 0.45	< 0.005
Luska	GWS - Group B Parameters	29-Aug-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	4	4	< 0.45	< 0.005
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.02	< 2	< 1	< 1	< 0.45	< 0.005
Newhill	GWS - Group B Parameters	23-Aug-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.06	< 2	3	8	< 0.45	< 0.005
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	< 0.02	< 2	2	2	1.49	< 0.005
Rathfalla	GWS - Group B Parameters	13-June-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	< 1	< 1	< 0.45	< 0.005
Shallee	GWS - Group B Parameters	13-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.03	< 2	1	3	< 0.45	< 0.005
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.02	< 2	1	8	< 0.45	< 0.005
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	< 1	< 1	< 0.005	< 0.005	< 0.1	< 0.003	< 0.005	< 0.005	< 0.005	0.02	< 2	5	2	< 0.45	< 0.005

			Parameter	Chloride	Chloroform	Chlorotoluron	Chlorpropham	Chromium	Clopyralid	Clostridium Per	Copper	Cyanide	Cypermethrin	Diazinon	Dibromochloro	Dicamba	Dichlobenil	Dichlorprop-p
			Max.	250	--	--	--	50	--	0	2	50	--	--	--	--	--	--
			Min.	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclus	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	cfu/100mls	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	25.3	3	< 0.005	< 0.005	< 1	0.023	0	0.01	< 10	< 0.012	< 0.005	2	< 0.005	< 0.005	< 0.005
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	19.7	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.009	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	31.2	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.001	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	27.8	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.003	< 10	< 0.012	< 0.005	3	< 0.005	< 0.005	< 0.005
Castleliney A	GWS - Group B Parameters	19-July-2023	-	21.6	< 2	< 0.005	< 0.005	< 1	0.017	0	0.011	< 10	< 0.012	< 0.005	1	< 0.005	< 0.005	< 0.005
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	9.8	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.02	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	15.6	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.001	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	27.5	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.004	< 10	< 0.012	< 0.005	3	< 0.005	< 0.005	< 0.005
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	14.4	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.004	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	26.7	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.006	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	14.6	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.005	< 10	< 0.012	< 0.005	3	< 0.005	< 0.005	< 0.005
Glenacunna	GWS - Group B Parameters	10-May-2023	-	12.8	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.001	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	32	75	< 0.005	< 0.005	< 1	< 0.005	0	0.011	< 10	< 0.012	< 0.005	5	< 0.005	< 0.005	< 0.005
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	20.7	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.009	< 10	< 0.012	< 0.005	2	< 0.005	< 0.005	< 0.005
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	22	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.022	< 10	< 0.012	< 0.005	3	< 0.005	< 0.005	< 0.005
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	22.7	10	< 0.005	< 0.005	< 1	< 0.005	0	0.01	< 10	< 0.012	< 0.005	3	< 0.005	< 0.005	< 0.005
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	17.7	< 2	< 0.005	< 0.005	5	< 0.005	0	0.01	< 10	< 0.012	< 0.005	1	< 0.005	< 0.005	< 0.005
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	42.9	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.006	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	14.1	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.004	< 10	< 0.012	< 0.005	1	< 0.005	< 0.005	< 0.005
Lacka	GWS - Group B Parameters	4-Sep-2023	-	25.6	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.009	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	30.5	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.01	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Luska	GWS - Group B Parameters	29-Aug-2023	-	29.6	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.025	< 10	< 0.012	< 0.005	1	< 0.005	< 0.005	< 0.005
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	24.5	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.005	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Newhill	GWS - Group B Parameters	23-Aug-2023	-	32.8	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.007	< 10	< 0.012	< 0.005	1	< 0.005	< 0.005	< 0.005
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	8.6	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.006	< 10	< 0.012	< 0.005	4	< 0.005	< 0.005	< 0.005
Rathfalla	GWS - Group B Parameters	13-June-2023	-	24.2	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.002	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Shallee	GWS - Group B Parameters	13-Sep-2023	-	17.2	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.008	< 10	< 0.012	< 0.005	2	< 0.005	< 0.005	< 0.005
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	16.8	< 2	< 0.005	< 0.005	< 1	< 0.005	0	0.005	< 10	< 0.012	< 0.005	< 1	< 0.005	< 0.005	< 0.005
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	23.6	5	< 0.005	< 0.005	< 1	< 0.005	0	0.015	< 10	< 0.012	< 0.005	5	< 0.005	< 0.005	< 0.005

			Parameter	Dieldrin	Diflufenican	Diuron	Enterococci	Epoxiconazole	Fluoride	Fluroxypyr	Glyphosate	Indeno(1,2,3-c,	Iron	Isoproturon	Lead	Linuron	Manganese	MCPA
			Max.	0.03	--	--	0	--	0.8	--	--	--	200	--	10	--	50	--
			Min.	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclus	µg/l	µg/l	µg/l	MPN/100mls	µg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.1	< 0.005	< 0.005	< 0.005	26	< 0.005	< 1	< 0.005	24	< 0.005
Castleliney A	GWS - Group B Parameters	19-July-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	13	< 0.005	1	< 0.005	2	< 0.005
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	10	< 0.005
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.7	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Glenacunna	GWS - Group B Parameters	10-May-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	10	< 0.005
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.2	< 0.005	0.006	< 0.005	44	< 0.005	< 1	< 0.005	1	< 0.005
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.2	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	1	< 0.005
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	5	< 0.005	2	< 0.005	< 1	< 0.005
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	6	< 0.005	< 1	< 0.005	5	< 0.005
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	11	< 0.005
Lacka	GWS - Group B Parameters	4-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	4	< 0.005
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Luska	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Newhill	GWS - Group B Parameters	23-Aug-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.2	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	2	< 0.005	9	< 0.005
Rathfalla	GWS - Group B Parameters	13-June-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Shallee	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	< 0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	4	< 0.005	< 1	< 0.005
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.1	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.005	< 0.005	0	< 0.005	0.2	< 0.005	< 0.005	< 0.005	< 5	< 0.005	< 1	< 0.005	< 1	< 0.005

			Parameter	Mecoprop Total	Mercury	Metaldehyde	Metazachlor	Nickel	Nitrite NO2	PAH Polycyclic	Pendimethalin	Pentachloroph	Pesticides Total	Picloram	Propyzamide	Selenium	Simazine	Sodium
			Max.	--	1	--	--	20	0.5	0.1	--	--	0.5	--	--	10	--	200
			Min.	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclus	µg/l	µg/l	µg/l	µg/l	µg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	mg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	0.023	< 0.005	< 0.005	< 5	< 0.005	14
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	10
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.05	< 0.005	< 0.005	< 5	< 0.005	14
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	48
Castleliney A	GWS - Group B Parameters	19-July-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	0.024	< 0.005	< 0.005	< 5	< 0.005	10
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	6
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	13
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	15
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	11
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	11
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.05	0.043	< 0.005	< 5	< 0.005	8
Glenacunna	GWS - Group B Parameters	10-May-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	4	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	7
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	2	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	16
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	0.007	10
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	13
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.05	< 0.005	< 0.005	< 5	< 0.005	12
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	23
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	8
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	10
Lacka	GWS - Group B Parameters	4-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	11
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	2	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	14
Luska	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	16
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	12
Newhill	GWS - Group B Parameters	23-Aug-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	0.005	15
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.05	< 0.005	< 0.005	< 5	< 0.005	9
Rathfalla	GWS - Group B Parameters	13-June-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	13
Shallee	GWS - Group B Parameters	13-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	9
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	< 0.016	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	11
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	< 0.005	< 0.5	< 0.005	< 0.005	< 1	0.019	< 0.02	< 0.005	< 0.005	< 0.012	< 0.005	< 0.005	< 5	< 0.005	8

			Parameter	Sulphate	Tetrachloroeth	Tetrachloroeth	THM Total	Total Organic C	Trichloroethene	Triclopyr	Boscalid
			Max.	250	--	10	100	--	--	--	0.1
			Min.	--	--	--	--	--	--	--	--
Entity	Sample Template	Sample Date	Analyst Conclus	mg/l	µg/l	µg/l	µg/l	mg/l	µg/l	µg/l	µg/l
Ashill	GWS - Group B Parameters	26-July-2023	-	10	<0.1	<0.2	9	2.7	<0.1	<0.005	<0.005
Ballinderry	GWS - Group B Parameters	29-Aug-2023	-	10	<0.1	<0.2	<5	1.6	<0.1	<0.005	<0.005
Carrigahorig / Milford	GWS - Group B Parameters	19-Apr-2023	-	21.7	<0.1	<0.2	<5	2.2	<0.1	<0.005	<0.005
Castelcranna / Carrigatogher	GWS - Group B Parameters	13-Sep-2023	-	5.2	<0.1	<0.2	10	1.5	<0.1	<0.005	<0.005
Castleliney A	GWS - Group B Parameters	19-July-2023	-	25.4	<0.1	<0.2	<5	3.3	<0.1	<0.005	<0.005
Corbally Portroe	GWS - Group B Parameters	21-June-2023	-	4	<0.1	<0.2	<5	1	<0.1	<0.005	<0.005
Couraguneeen	GWS - Group B Parameters	16-May-2023	-	7.6	<0.1	<0.2	<5	1	<0.1	<0.005	<0.005
Cunnahurt/Knockalton	GWS - Group B Parameters	13-June-2023	-	11.7	<0.1	<0.2	7	1.5	<0.1	<0.005	<0.005
Drombane Ballina	GWS - Group B Parameters	21-June-2023	-	8.4	<0.1	<0.2	<5	1	<0.1	<0.005	<0.005
Frolic Carney	GWS - Group B Parameters	29-Aug-2023	-	14.2	<0.1	<0.2	6	1.5	<0.1	<0.005	<0.005
Garrymore	GWS - Group B Parameters	9-Feb-2023	-	5.9	<0.1	<0.2	7	2.1	<0.1	<0.005	<0.005
Glenacunna	GWS - Group B Parameters	10-May-2023	-	2.9	<0.1	<0.2	<5	1	<0.1	<0.005	<0.005
Graigue Pouldine Zone 1: Graigue	GWS - Group B Parameters	26-July-2023	-	14.1	<0.1	<0.2	101	4.2	<0.1	<0.005	<0.005
Graigue Pouldine Zone 2: Turtulla	GWS - Group B Parameters	26-July-2023	-	13.3	<0.1	<0.2	6	1.7	<0.1	<0.005	<0.005
Gurteenakilla	GWS - Group B Parameters	13-Sep-2023	-	7.9	<0.1	<0.2	9	1.7	<0.1	<0.005	<0.005
Kilbarron	GWS - Group B Parameters	19-Apr-2023	-	32.6	<0.1	<0.2	21	3	<0.1	<0.005	<0.005
Kilcoran Group Water Scheme	GWS - Group B Parameters	10-May-2023	-	4.5	<0.1	<0.2	<5	1.2	<0.1	<0.005	<0.005
Killeen A	GWS - Group B Parameters	13-Sep-2023	-	14.5	<0.1	<0.2	<5	1.6	<0.1	<0.005	<0.005
Knock Roscrea	GWS - Group B Parameters	16-May-2023	-	9.8	<0.1	<0.2	<5	1.7	<0.1	<0.005	<0.005
Lacka	GWS - Group B Parameters	4-Sep-2023	-	13	<0.1	<0.2	<5	1.1	<0.1	<0.005	<0.005
Lisheenacloonta	GWS - Group B Parameters	13-Sep-2023	-	14	<0.1	<0.2	<5	3.1	<0.1	<0.005	<0.005
Luska	GWS - Group B Parameters	29-Aug-2023	-	22.1	<0.1	<0.2	11	2.6	<0.1	<0.005	<0.005
Mota/ Coolbawn	GWS - Group B Parameters	29-Aug-2023	-	8.5	<0.1	<0.2	<5	1.3	<0.1	<0.005	<0.005
Newhill	GWS - Group B Parameters	23-Aug-2023	-	19.3	<0.1	<0.2	12	1.9	<0.1	<0.005	<0.005
Patrickswell	GWS - Group B Parameters	19-Apr-2023	-	6.5	<0.1	<0.2	9	4.5	<0.1	<0.005	<0.005
Rathfalla	GWS - Group B Parameters	13-June-2023	-	21	<0.1	<0.2	<5	0.9	<0.1	<0.005	<0.005
Shallee	GWS - Group B Parameters	13-Sep-2023	-	41.5	<0.1	<0.2	7	1.6	<0.1	<0.005	<0.005
The Pike Ballingarry	GWS - Group B Parameters	4-Sep-2023	-	10.6	<0.1	<0.2	11	1.2	<0.1	<0.005	<0.005
Tonagha / Drish / Galboola	GWS - Group B Parameters	26-July-2023	-	9.4	<0.1	<0.2	17	3.2	<0.1	<0.005	<0.005